

Experimental and Numerical Investigations of Forced Convection in Tube-Type Heat Exchanger

Christian Okechukwu Osueke, Igbinosalkpotokin,

Department of Mechanical Engineering, Landmark University, Omu-Aran, Kwara State Nigeria

Abstract:- Experimental and numerical studies of forced convection heat transfer in tube-type heat exchanger consisting four columns of five cylindrical tubes arranged so that every second column is displaced (i.e staggered configuration) were carried out. Experiments were conducted to determine the effects of flow pattern on heat transfer and pressure drop within the heat exchanger and the heat transfer dependence on position. In the analytical approach, the dimensionless representations of the rates of forced convection (i.e Nusselt number) and pressure loss (i.e drag coefficient) were obtained. The numerical simulation is carried out using **FEMLAB 3.0** and the results compared favourably with the experimental. The flow visualization features such as boundary layer developments between tubes, formation of vortices, local variations of the velocity and temperature distribution within the heat transfer device were revealed by numerical solution. The results showed that the average Nusselt number increases with increasing Reynolds number and the heated element position in the bank. The drag coefficient decrease with increasing Reynolds numbers.

Keywords:- Tube-type heat exchangers, staggered tube bank, forced convection.

I. INTRODUCTION

The process of forced convection heat transfer to or from tube bank was the subject of many theoretical and experimental studies because of their relevance in many engineering applications. This process is significant in the design of heat transfer process devices such as boiler for steam generation and cooling coil of air conditioning system.

The increasing interest in developing compact, and high efficient heat exchanger motivated researchers to study heat transfer from tube bank of circular cross section (Keys and London, 1998).

The studied tube-type heat exchanger is a staggered arrangement of four columns of five parallel cylinders. The configuration is determined by tube diameter and longitudinal and transverse pitches which are distances between tube centres. In this heat transfer device, fluid flow perpendicular to the tube bank thus simulating a typical cross flow heat exchanger, used in many industrial applications such as boilers, automotive, air conditioner, etc.

The fluid flow conditions within the bank are dominated by turbulence because most heat exchangers operate at high Reynolds numbers (Re) and induced vortex shedding which enhanced the heat transfer process. The turbulence intensity and its generation are governed by the bank geometry and Re . It was observed that with shorter transverse pitches, the velocity fluctuations become more intensive. The turbulence level of the main flow can influence fluid flow only over the first and second rows (Mehrabian, 2007). A tube bank acts as a turbulent grid and establishes a particular level of turbulence. The heat transfer conditions stabilize, such that little change occurs in the convection coefficient for tube beyond the fifth row tube (Yoo et al, 2007).

For optimal design of heat transfer process device and the determination of its operational performance parameters, the drag, and heat transfer associated with fluid flow over the tube surfaces have to be known. Because a sudden changes in these quantities can lead to hysteresis and poor device functionality (Yukio et al, 2010).

Although reasonable number of researchers had conducted experiments and numerical analyses on fluid flow and heat transfer at the tube bank, but different correlation equations have been proposed to predict the heat transfer or the Nusselt number. The results obtained depend on the geometric configuration, number of tube rows, and the Reynolds number. For example, (Žukauskas, 1987) obtained a correlation given as

$$Nu = C Re^m Pr^n \left(\frac{Pr}{Pr_w} \right)^{0.25} \quad 1$$

where Pr_w and Pr represent the Prandtl numbers evaluated at the wall temperature and the bulk mean temperature, respectively. Re denotes the Reynolds number evaluated at the bulk mean temperature, and it is based on the average velocity through the least cross section formed by the tube array. The constants C , m , and n vary depending on the Reynolds number and tube bundle geometry and it can be found in many heat transfer textbooks.